

PANELBOARD: H2
WV: 250 AMP
SUB: 400 AMP
VOLTAGE: 208/120
PHASE: 3
WIRE: 4
TYPE: NEW BOLT-ON
MOUNTING SURFACE:
LOCATION: TEST BAY

PANELBOARD: L3
WV: 225 AMP
SUB: 225 AMP
VOLTAGE: 208/120
PHASE: 3
WIRE: 4
TYPE: NEW BOLT-ON
MOUNTING SURFACE:
LOCATION: ELECTRICAL ROOM

PANELBOARD: L1-A
WV: 125 AMP
SUB: 125 AMP
VOLTAGE: 208/120
PHASE: 3
WIRE: 4
TYPE: NEW BOLT-ON
MOUNTING SURFACE:
LOCATION: MANUFACTURING ROOM

PANELBOARD: L1
WV: 400 AMP
SUB: 400 AMP
VOLTAGE: 208/120
PHASE: 3
WIRE: 4
TYPE: NEW BOLT-ON
MOUNTING SURFACE:
LOCATION: MAIN ELECTRICAL ROOM

PANELBOARD: H3
WV: 80 AMP/3 LINE
SUB: 80 AMP
VOLTAGE: 480/277
PHASE: 3
WIRE: 4
TYPE: NEW BOLT-ON
MOUNTING SURFACE:
LOCATION: TEST BAY

PANELBOARD: H1
WV: 400 AMP
SUB: 400 AMP
VOLTAGE: 480/277
PHASE: 3
WIRE: 4
TYPE: NEW BOLT-ON
MOUNTING SURFACE:
LOCATION: ELECTRICAL ROOM



Table with columns: NO., DATE, REVISION, BY.

ALTEC DESIGN ASSURANCE ONE LINE RISER & PANEL SCHEDULE

Table with columns: ENGINEER, CHECKED BY, JOB NO., DRAWN BY, SCALE, DATE, DNS.